



EVPU®

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0341
of September 12, 2012

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Optical Smoke & Heat Detector FDOT500

Is connected on Control and indicating equipment, with which has declared compatibility and is powered from it (for conditions of use for the product see the attached appendix)

placed on the market by
URMET S.p.A.

Via Bologna 188/C, 10154 Torino, Italy

and produced in the factory
VAT No. IT05288880965

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPU a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

**EN 54-7: 2000/A2: 2006, EN 54-5: 2000/A1:2002,
EN 54-17: 2005/ AC: 2007**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on September 12, 2012 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Marek H u d á k

The 
1293

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

044486

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 1 FCO 69-07 rev.3

Appendix to EC Certificate of Conformity No.1293 – CPD – 0341

The details and conditions of use for the **Optical Smoke Detector FDOT500**, placed on the market by **URMET S.p.A.** and distributed by **URMET S.p.A.** are:

To be used in accordance with the supplies installation instructions and in conjunction with the following bases and heat classification:

Bases:

SD500 Universal base

SD500R Universal base with alarm repeater output

Heat classification

Class A1




Marek H u d á k

